

Fluoride in the distribution system and at water plants

- Note:
1. "Level (mg/L)" column indicates the fluoride level at the location on that day sample was taken;
 2. "Plant Level (mg/L)" indicates the fluoride level at the water treatment plant on the day when sample was taken;
 3. Fluoride levels are very consistent. The influent level at wastewater plant was maybe because the rain event starting at about 5 pm on that day, which diluted level in the wastewater plant influent.

DATE	LOCATION	LEVEL (mg/L)	PLANT LEVEL (mg/L)
06/19/2014	Wastewater Plant Influent	0.4	0.8
06/19/2014	Wastewater Plant effluent	0.7	0.8
06/20/2014	Wastewater plant lab bathroom	0.7	0.8
06/20/2014	B.P. GAS STATION	0.8	0.8
06/20/2014	FAZOLIS	0.8	0.8
06/20/2014	FAMILY EXPRESS NORTH	0.8	0.8
06/20/2014	WENDY'S	0.7	0.8
06/20/2014	NEW DRAGON	0.7	0.8
06/20/2014	651 WOODSTREAM XING	0.7	0.8
06/21/2014	PNC GRAD	0.6	0.7
06/21/2014	CAMPBELL TANK	0.7	0.7
06/21/2014	MCDONALDS	0.7	0.7
06/21/2014	FAMILY EXPRESS CALUMET	0.7	0.7
06/21/2014	RICH'S GAS STATION	0.7	0.7
06/22/2014	TACO BELL	0.6	0.8
06/22/2014	LADYBUG CLEANERS	0.7	0.8
06/22/2014	DOLLAR GENERAL	0.6	0.8
06/22/2014	BASKIN ROBBINS	0.8	0.8
06/22/2014	B.P.	0.7	0.8
06/23/2014	ST. PAULS CHURCH	0.6	0.7
06/23/2014	FIRST BAPTIST CHURCH	0.7	0.7
06/23/2014	GOLFVIEW APARTMENTS	0.6	0.7
06/23/2014	CHRIST LUTHERN CHURCH	0.7	0.7
06/23/2014	AUTOZONE	0.7	0.7
06/24/2014	GLENROSE NORTH PARK	0.6	0.7
06/24/2014	VALE PARK ANIMAL HOSP.	0.7	0.7
06/24/2014	B.P.	0.6	0.7

when the

as lower
d the fluoride